



FAN COIL UNIT SELECTION CHECKLIST

Fill out this form and return to our customer service department for a quick-turn quote. Email: fancoils@wfc-fc.com Fax: 1-866-287-9388

PROJECT NAME: _____
 PROJECT CITY & STATE: _____
 DISTRIBUTOR COMPANY: _____
 DISTRIBUTOR CONTACT: _____
 DISTRIBUTOR PHONE: _____
 DISTRIBUTOR E-MAIL ADDRESS: _____
 UNIT QUANTITY: _____

UNIT DEFINITION

FAN COIL MODEL	
	H or LH - HORIZONTAL LOW STATIC
	C or HH - HORIZONTAL HIGH STATIC
	L or LV - VERTICAL WALL UNIT
	LS - VERTICAL LOW SILHOUETTE
	V or CV - VERTICAL HIGH STATIC
	ER - VERTICAL STACK
	AH - HORIZONTAL BELT DRIVE
	AV - VERTICAL BELT DRIVE
CABINET STYLE	
	BASIC
	DELUXE
	FLUSH (LH/HH/CH ONLY)
	RETURN AIR -PLENUM (LH/HH ONLY)
	RECESSED (LV/LS ONLY)
	SLOPED (LV/LS ONLY)
	WRAP SLOPED (LV/LS ONLY)
SYSTEM TYPE	
	2-PIPE HYDRONIC COOLING
	2-PIPE HYDRONIC HEATING
	2-PIPE HC W/AUX ELECTRIC HEAT
	2-PIPE HC W/TOTAL ELECTRIC HEAT
	2-PIPE HYDRONIC SEASONAL CHANGEOVER
	4-PIPE HYDRONIC COOLING & HEATING
	DX
	DX & HYDRONIC HEAT
	DX & ELECTRIC HEAT
AIR FLOW	
	(MUST BE ENTERED) CFM
	(MUST BE ENTERED) EXTERNAL STATIC
	TOTAL COOLING BTU
	TOTAL HEATING BTU
MOTOR TYPE	
	STANDARD
	ECM CONSTANT AIRFLOW STANDARD (3 SPEED)
	ECM CONSTANT AIRFLOW USER INPUT (3 SPEED)
	ECM VARIABLE MOTOR

UNIT ACCESSORIES

FILTER	
	1" THROWAWAY
	2" THROWAWAY
	1" PLEATED
	2" PLEATED
	1" WASHABLE
	SPARE FILTER
COIL	
	LEFT HAND
	RIGHT HAND
	LEFT HAND COOLING/RIGHT HAND HEATING
	RIGHT HAND COOLING/LEFT HAND HEATING
	DRAIN VALVE
DRAIN PAN	
	STANDARD
	STAINLESS STEEL
VALVE PACKAGE	
	2-WAY CONTROL VALVE (ON/OFF)
	3-WAY CONTROL VALVE (ON/OFF)
	2-WAY CONTROL VALVE (MODULATING)
	3-WAY CONTROL VALVE (MODULATING)
	BALL VALVES
	FLEX HOSES
	FIXED FLOW CONTROL
	MANUAL FLOW CONTROL
	PT PORTS
	UNIONS
	AUTO AIR VENT
	MANUAL AIR VENT
ELECTRICAL - CONTROLS	
	24V TRANSFORMER AND RELAY PACKAGE
	TERMINAL STRIP
	FUSED DISCONNECT
	NON-FUSED DISCONNECT
	CONDENSATE FLOAT SWITCH
	3-SPEED FAN SWITCH
	THERMOSTAT

MOTOR VOLTAGE			
	115V/1/60		208V/3/60
	208V/1/60		230V/3/60
	230V/1/60		460V/3/60
	277V/1/60		